Tecumseh Township

Decks & Porches

Zoning Requirements

Submit a site plan to and discuss your project with the Zoning Administrator for approval.

Building Code Considerations – 2 sets of construction drawings showing the size and grade of lumber, railing height, height off grade

Section R314.1 – Stairways shall not be less than 36" wide.

<u>Section R314.2</u> – Treads shall not be less than 9 inches deep and Risers shall not be more than 8 ¼ inches high.

Section R314.2.1 – Open risers are permitted if the opening created is not over 4 inches high and the deck is not over 30" high, otherwise they have to be closed. If the riser is closed and less than 11 inches then a nosing of 34 to 1 1/4 inch shall be provided.

<u>Section R315.1</u> – Handrails shall be no lower than 34 inches and no higher than 38 inches. The ends shall terminate into a wall or newel post. They shall be provided on one side of the stairway.

<u>Section 315.2</u> – The handrail shall be graspable. 1 ¼ cross-section minimum to 2 5/8 maximum. Other approved shapes are acceptable. For approved types of handrails visit <u>www.michigan.gov/cis</u>. Click on Construction Codes and Fire Safety, then click on publications, and then technical bulletins. <u>Look for publication No. 13</u>.

<u>Section 316.1</u> – Decks, porches, balconies, or raised floors more than 30 inches above grade shall have a 36 inch guardrail, below 30 inches no guardrail is required. Open side of stairways more than 30 inches shall have a guardrail of 34 inches.

<u>Section 316.2</u> – Required guardrails shall have intermediate rails or ornamental closures that do not allow a 4-inch diameter sphere to be passed through them. The triangular openings formed by the treads and riser shall not allow a 6-inch diameter sphere to be passed through them.

<u>Section 315.1</u> – Regardless of deck or porch height – If you have 3 risers or more a continuous handrail is required.

Revised: 9/9/03



